



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS1B 15 10 81102 002

Certificate Holder: **Mapleland Corporation Sdn Bhd**
Bandar Puchong Jaya
No.2 Jalan Kenari 10
47100 Puchong
MALAYSIA

Certification Mark:

Product: Fire Dampers

Brand Name: FSD60

Model(s): FSD60

Product Details: Integrity: 240mins
Maximum size:
800mm wide x 1250mm high (single module);
1600mm wide x 1250mm high (2x1 modules)

Galvanized steel multi-blades type fire damper applicable for vertical mounting
Former CoC 012220

Standard(s): SS 333:2012 CI 6.3, 6.4, 6.5 & 6.6

Country of Origin: Malaysia

Test Report(s): See CoC Appendix (1pg)

Issued on: 2015-10-19

Valid until: 2018-11-24

Products listed under Class 1B must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 2

Vice-President (Certification Department)
TÜV SÜD PSB

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv-sud-psb.sg



PSB Singapore

PRODUCT LISTING SCHEME APPENDIX

TO CERTIFICATE OF CONFORMITY NUMBER: CLS1B 15 10 81102 002

Date of Issue : 2015-10-19

Issued To : **Mapleland Corporation Sdn Bhd**
Bandar Puchong Jaya
No.2 Jalan Kenari 10
47100 Puchong
MALAYSIA

Test Report(s) : PSB Test S09MEC05432/RAH
PSB Test S08MEC04318/TSM
VIPAC Test 90S-08-0051-TRP-252070-1
PSB Assessment 7191120596-MEC15-JC

Vice President (Certification Department)
TÜV SÜD PSB