


ASLI MECHANICAL SDN. BHD..

Airflow and Acoustic Research and Development Study of 4-way Square Ceiling Diffusers

*This Laboratory is accredited by the National Association of Testing Authorities, Australia.
The results reported herein have been determined in accordance with the terms of
accreditation, and shall not be reproduced except in full.*



N.A.T.A. Report No. 302849-1

Prepared by
Vipac Engineers & Scientists Ltd
August, 2001



DOCUMENT CONTROL FORM

Airflow And Acoustic Research And Development Study of 4-way Square Ceiling Diffusers	
FILE:	REPORT CODE:
GT302849-1.doc	MA 77
PREPARED FOR:	PREPARED BY:
ASLI MECHANICAL SDN. BHD. No. 2, Jalan Kenari 10, Bandar Puchong Jaya Off Jalan Puchong, 47100 Puchong, Selangor Darul Ehsan, Malaysia Contact: Mr Walter Wong Phone: 603 8075 4933 Fax: 603 8075 4911	Vipac Engineers & Scientists Ltd., Victorian Technology Centre, 275 Normanby Road, Port Melbourne VIC. 3207 AUSTRALIA Phone: (03) 9647-9700 Fax: (03) 9646-4370


AUTHOR:	 Greg Theodoridis Project Engineer	24/8/01 Date:												
REVIEWED BY:	 Norm Broner N.A.T.A. Signatory	24/8/01 Date:												
REVISION HISTORY:	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 20%;">Issue No.</th> <th style="width: 30%;">Date Issued</th> <th style="width: 50%;">Reason/Comments</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">0</td> <td style="text-align: center;">August, 2001</td> <td style="text-align: center;">Original</td> </tr> </tbody> </table>		Issue No.	Date Issued	Reason/Comments	0	August, 2001	Original						
Issue No.	Date Issued	Reason/Comments												
0	August, 2001	Original												
DISTRIBUTION:	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;">This is Copy No. ____</th> <th style="width: 20%;">Issue No.</th> <th style="width: 50%;">Location</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">1</td> <td style="text-align: center;">0</td> <td>Client</td> </tr> <tr> <td style="text-align: center;">2</td> <td style="text-align: center;">0</td> <td>Project File</td> </tr> <tr> <td style="text-align: center;">3</td> <td style="text-align: center;">0</td> <td>Vipac Melbourne Library</td> </tr> </tbody> </table>		This is Copy No. ____	Issue No.	Location	1	0	Client	2	0	Project File	3	0	Vipac Melbourne Library
This is Copy No. ____	Issue No.	Location												
1	0	Client												
2	0	Project File												
3	0	Vipac Melbourne Library												
KEY WORDS:	Noise, Airflow, Square Ceiling Diffuser													

TABLE OF CONTENTS

DOCUMENT CONTROL FORM.....	2
1.0 INTRODUCTION	4
2.0 UNIT UNDER TEST	4
3.0 TEST CONDITIONS AND APPLICABLE STANDARDS.....	4
4.0 TEST SET UP AND PROCEDURE	5
5.0 INSTRUMENTATION	9
6.0 ORDERS OF ACCURACY	9
7.0 RESULTS	10

1.0 INTRODUCTION

This report presents the results of acoustic and airflow development tests carried out on 3 sizes of 4-way square ceiling diffuser units supplied by ASLI MECHANICAL SDN. BHD., as described below.

This report is issued as a NATA certified report under the terms of Vipac's NATA accreditation No's 1163 and 1506.

2.0 UNIT UNDER TEST

Table 1 : Description of Units Under Test

#	Unit Description	Face Size (mm)	Reducer Neck Size (mm)
1	Square 4-way Ceiling Diffuser with Reducer	600 x 600	195 x 195
2		600 x 600	245 x 245
3	Throw Pattern 20°-30° From Horizontal	600 x 600	295 x 295

3.0 TEST CONDITIONS AND APPLICABLE STANDARDS

The unit was tested at a range of flow conditions, as shown on the Test Certificates.

The test set up was in general accordance with Air Diffusion Council (USA) Equipment Test Code 1062: GRD-84. Measurements were taken in general accordance with the following standards:

ACOUSTICS

Australian Standard 1217.2-1985. "Acoustic - Determination of Sound Power Levels of Noise Sources Part 2 - Precision Methods for Broad-Band Sources in Reverberation Rooms".

AIRFLOW

Air Diffusion Council (USA) Equipment Test Code 1062: GRD-84.

THROW & STATIC PRESSURE DROP

Air Diffusion Council (USA) Equipment Test Code 1062: GRD-84.

4.0 TEST SET UP AND PROCEDURE

Vipac's Reverberation Test Room has a volume of 170m^3 has been qualified in accordance with the procedures in AS 1217.2 - 1985 for determination of sound power in octave bands with Centre Frequencies from 125 Hz to 8000 Hz.

The unit under test was set up in the Air Distribution (Reverberation) Test Chamber and connected to a quiet air supply.

The unit was supplied with ambient temperature air at the specified airflows. The environmental test conditions in the reverberation chamber varied for each test within the following ranges:

Test Air Temperature	12 degrees C $\pm$ 2.0 degree C
Room Air Temperature	14 degrees C $\pm$ 2.0 degree C
Barometric Pressure	1035 millibar $\pm$ 5 millibar
Relative Humidity	60 $\pm$ 10%

Following calibration checks, sound pressure levels were measured and converted to sound power levels using the comparison method of AS1217.2 - 1985 (ie. using a reference sound source of known Sound Power to determine room correction).

Airflow rate was measured using orifice plates. Static pressure drop was recorded using a (Static Pressure) probe and an inclined manometer. Throw was measured using a hotwire anemometer. Figure 1 shows the test set up. Figure 2 shows the test unit.





Figure 1: Schematic of Test Set-up




a) Front View




b) Rear View, from left, reducer sizes 295x295, 245x245, 195x195

Figure 2 : Test Samples



c) Front View, Blade Module removed



d) Close view of Clip which supports Blade Module

Figure 2 (cont') : Test Samples

5.0 INSTRUMENTATION

INSTRUMENT	MAKE & MODEL	CALIBRATION		SERIAL NO.
		BY	DATE	
Sound Level Meter	LD2900	Vipac	May 2001	A0316
Microphone	B&K 4145	Vipac	May 2001	25415619
Acoustic Calibrator	B&K 4230	Vipac	7/6/00	860700
Sound Power Reference Source	Pope	Vipac	1/5/2001	-
Manometers (2)	Airflow Developments Type 504	Gas Technology Services	June 2001	36862 PM6-168
Orifice Plates	Vipac	Vipac	May 2001	-
Hotwire Probe	TSI 8330	TSI	12/11/97	97110174
Thermometer	Digital T200KC	-	-	-

6.0 ORDERS OF ACCURACY

<u>Sound Pressure Level:</u>	Octave Band Centre Frequency (Hz)	Standard Deviation (1) (dB)
	125	± 3.0
	250	± 2.0
	500 to 4000	± 1.5
	8000	± 3.0

Pressure Drop: $\pm 5\%$ or 0.5 Pa whichever is greater

Airflow: $\pm 5\%$ or 10 l/s whichever is greater

7.0 RESULTS


The results obtained are shown in the attached Test Certificates.

Report Prepared by:

VIPAC ENGINEERS AND SCIENTISTS LTD.



.....
GREG THEODORIDIS
PROJECT ENGINEER



.....
NORM BRONER
N.A.T.A. SIGNATORY

TEST CERTIFICATE No. 1

ACOUSTIC AND AIRFLOW PERFORMANCE TEST OF AIR OUTLETS AND INLETS

SUPPLIED BY: ASLI MECHANICAL SDN. BHD.
TESTED BY: VIPAC ENGINEERS & SCIENTISTS LTD
TEST DATE: 16/8/2001
CLIENT: ASLI MECHANICAL SDN. BHD.
UNIT: Square 4-way Ceiling Diffuser with Reducer
Reducer Neck Size: 295mm x 295mm
Face Size: 600mm x 600mm
Throw Pattern: 20-30° from Horizontal

TEST CONDITIONS				SOUND POWER LEVEL, dB re 1E-12 W						
				OCTAVE BAND CENTRE FREQUENCY (Hz)						
Qs (l/s)	Ps (Pa)	T (m)	NR	125	250	500	1000	2000	4000	8000
207	13	3	17	<40.8	36.2	27.5	26.9	<19.4	<17.5	<18.0
237	17	3.4	21	<43.8	37.4	29.7	30.8	21.9	<18.0	<18.8
282	23	3.7	28	<44.4	41.6	40.4	37.9	30.6	<19.8	<19.1
334	31	4	35	46.1	41.1	48.5	43.4	37.8	27.4	<19.7
399	43	>4	38	49.4	45.4	51.6	48.2	44.6	34.2	<22.4

LEGEND

Qs - Primary Air Flow Rate (l/s)
Ps - Supply Static Pressure (Pa)
< - Insufficient margin above background noise to allow accurate determination
> - Length of throw greater than that able to be measured
NR - Noise Rating number based upon room absorption of 10 dB
T - Throw in meters to a terminal velocity of 0.25m/s



Greg Theodoridis
PROJECT ENGINEER



Norm Broner
N.A.T.A. SIGNATORY

This laboratory is accredited by the National Association of Testing Authorities, Australia.

The tests reported herein have been performed in accordance with its terms of accreditation. This document shall not be reproduced except in full.

TEST CERTIFICATE No. 2

ACOUSTIC AND AIRFLOW PERFORMANCE TEST OF AIR OUTLETS AND INLETS

SUPPLIED BY: ASLI MECHANICAL SDN. BHD.
TESTED BY: VIPAC ENGINEERS & SCIENTISTS LTD
TEST DATE: 16/8/2001
CLIENT: ASLI MECHANICAL SDN. BHD.
UNIT: Square 4-way Ceiling Diffuser with Reducer
Reducer Neck Size: 245mm x 245mm
Face Size: 600mm x 600mm
Throw Pattern: 20-30° from Horizontal


TEST CONDITIONS				SOUND POWER LEVEL, dB re 1E-12 W OCTAVE BAND CENTRE FREQUENCY (Hz)						
Qs (l/s)	Ps (Pa)	T (m)	NR	125	250	500	1000	2000	4000	8000
137	12	2.7	17	<40.5	<31.3	29.1	25.5	21.7	<18.1	<19.0
165	17	3.3	21	<41.7	<32.8	31.7	30.6	22.2	<19.0	<19.0
207	26	3.7	31	<42.9	36.4	45.2	41.4	31.3	<20.3	<19.1
250	36	4	37	45.9	41.3	49.3	46.6	39.0	28.3	<19.7
299	50	>4	43	52.2	46.6	51.2	53.0	46.0	36.3	23.5

LEGEND

Qs - Primary Air Flow Rate (l/s)
Ps - Supply Static Pressure (Pa)
< - Insufficient margin above background noise to allow accurate determination
> - Length of throw greater than that able to be measured
NR - Noise Rating number based upon room absorption of 10 dB
T - Throw in meters to a terminal velocity of 0.25m/s



Greg Theodoridis
PROJECT ENGINEER



Norm Broner
N.A.T.A. SIGNATORY

This laboratory is accredited by the National Association of Testing Authorities, Australia.

The tests reported herein have been performed in accordance with its terms of accreditation. This document shall not be reproduced except in full.

TEST CERTIFICATE No. 3

ACOUSTIC AND AIRFLOW PERFORMANCE TEST OF AIR OUTLETS AND INLETS


SUPPLIED BY: ASLI MECHANICAL SDN. BHD.
TESTED BY: VIPAC ENGINEERS & SCIENTISTS LTD
TEST DATE: 19/8/2001
CLIENT: ASLI MECHANICAL SDN. BHD.
UNIT: Square 4-way Ceiling Diffuser with Reducer
 Reducer Neck Size: 195mm x 195mm
 Face Size: 600mm x 600mm
 Throw Pattern: 20-30° from Horizontal

TEST CONDITIONS				SOUND POWER LEVEL, dB re 1E-12 W						
				OCTAVE BAND CENTRE FREQUENCY (Hz)						
Qs (l/s)	Ps (Pa)	T (m)	NR	125	250	500	1000	2000	4000	8000
107	17	3	17	<41.2	<33.4	29.3	27.1	<17.9	<16.1	<18.2
126	22	3.6	23	<42.5	<35.4	34.2	33.1	24.2	<16.8	<18.2
147	29	4	28	<43.0	38.0	39.1	38.0	30.8	<20.0	<18.4
170	40	>4	35	<45.8	42.7	44.9	44.9	37.5	27.2	<19.0
201	57	>4	41	49.5	48.2	47.7	50.7	44.6	34.6	<22.0

LEGEND

Qs - Primary Air Flow Rate (l/s)
 Ps - Supply Static Pressure (Pa)
 < - Insufficient margin above background noise to allow accurate determination
 > - Length of throw greater than that able to be measured
 NR - Noise Rating number based upon room absorption of 10 dB
 T - Throw in meters to a terminal velocity of 0.25m/s


 Greg Theodoridis
 PROJECT ENGINEER


 Norm Broner
 N.A.T.A. SIGNATORY

This laboratory is accredited by the National Association of Testing Authorities, Australia.

The tests reported herein have been performed in accordance with its terms of accreditation. This document shall not be reproduced except in full.